



Step Lift Platform Specification

Pit: No pit required

Drive: Electro-hydraulic

Speed: 0.1m/sec

Travel: Max 1m (Lower FFL to Upper FFL)

Power: 240v 20amp 1 phase 50hz

Stops: 2

Colour: Standard - RAL 7035

Lift platform: Special - RAL

Colour: Standard - RAL 7012

Upper gate: Special - RAL

Upper Gate Type

Standard - Manual interlock (Push to open)

Special - Motorized interlock (opens with motor)

Upper Gate Handing

Right hand handing

(Drawing shows - left hand)

Left hand handing

Upper call station

Standard - Gate mounting (opposite to handing side)

Special - Wall mounted (surface mounted)

Special - Wall mounted (recessed)

Lower call station

Standard - Wall mounted (surface mounted)

Special - Wall mounted (recessed)

Hydraulic pump

Housed in section below the gate. If travel is less than 400mm an external Pump box is required

Building work required

- ①- Provide 20amp 1 phase power to lockable isolator (close to lift).
- ②- Provide a level surface under the lift base.
- ③- Provide clear delivery access to lift location. A minimum of 1370mm width.
- ④- Provide adequate fixing point for the upper gate.
- ⑤- Provide 20 mm conduit + draw wire from lower call station to under gate frame.
- ⑥- If wall mounted call station on upper landing, also provide a conduit to under gate.
- ⑦- Provide a cable from the isolator to under the gate frame + a 3m extra tail.
- ⑧- Provide finish floor on the lower and upper landing.
- ⑨- Provide base under lift to withstand a load of 500 kg.

Platform Lift Company

785 Privately Road, Dee Why
NSW 2099
Tel - 1300 884960
Fax - 02 88505046
Email - info@platformliftco.com.au
website - www.platformliftco.com.au

TITLE

Independence Step Lift - Adjacent

DWG NO.

250 - INDEPENDENCE ADJ

REV

A

SCALE

NTS

DATE

12/03/09

DRAWN

JS